

# Annual Drinking Water Quality Report

## REND LAKE INTERCITY WATER SYSTEM

IL0555100

**Annual Water Quality Report for the period of January 1 to December 31, 2024**

**This report is intended to provide you with important information about your drinking water and the efforts made by the REND LAKE INTERCITY WATER SYSTEM to provide safe drinking water.**

**The source of drinking water used by REND LAKE INTERCITY WATER SYSTEM is Surface Water. For more information regarding this report contact:**

**Name: Tony Furlow**

**Phone: 618-439-4394**

**Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.**

### Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Source Water Assessment

Rend Lake is utilized by the Rend Lake Intercity Water System (Facility # IL0555100) to provide water to 67 communities in Williamson, White, Saline, Perry, Jefferson, Jackson, Hamilton and Franklin Counties. This facility draws water from Rend Lake through one surface water intake (IEPA #IN70290). The supply provides approximately 15 million gallons per day to 67 satellite supplies with an estimated population of 175,000 people. Illinois EPA considers all surface water sources of public water supply to be susceptible to potential pollution problems, hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection. Primary sources of pollution in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion. Our surface supply location is INTAKE (70290) REND LAKE SURFACE.

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. These meetings are on the 4th Monday of each month at our administration office located at 11231 Marcum Branch Rd., Benton, IL. The source water assessment for our supply has been completed by the Illinois EPA. If you would like to view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at: <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>

## 2024 Regulated Contaminants Detected

### Lead and Copper

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rend Lake Intercity Water System is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Rend Lake Intercity Water System at 618-439-4394. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available at: <http://www.epa.gov/safewater/lead>

#### Definitions:

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Action Level Goal (ALG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.

Copper Range: Non-detect (ND) to 0.0584 ppm

Lead Range: All samples were Non-detect (ND)

To obtain a copy of the system's lead tap sampling data, please call Tony Furlow, Water / Sewer Manager, at 618-439-4394 ext. 222.

Our community water supply has developed a service line material inventory. To obtain a copy of our service line inventory, please visit:

<https://rendlake.org/wp-content/uploads/2024/07/RLCD-MATERIAL-INVENTORY-FINAL-2024.pdf>

#### Date Sampled: 8/15/23 (Triennial)

Lead MCLG	Lead Action Level (AL)	Lead 90th Percentile	# Sites Over Lead AL	Copper MCLG	Copper Action Level (AL)	Copper 90th Percentile	# Sites Over Copper AL	Likely Source of Contamination
0 ppb	15 ppb	0 ppb	0	1.3 ppm	1.3 ppm	0.0524	0	Corrosion of household plumbing systems; Erosion of natural deposits

### Water Quality Test Results

**Definitions:** The following tables contain scientific terms and measures, some of which may require explanation.

**Avg.:** Regulatory compliance with some MCL's is based on running annual average of monthly samples.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the Maximum Contaminant Level Goal as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of disinfectant in drinking water below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**N/A:** not applicable.

**ND:** Non-detect

**ppm:** milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

**ppb:** micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

**pCi/L:** Picocuries per Liter (a measure of radioactivity)

**Treatment Technique:** A required process intended to reduce the level of a contaminant in drinking water.

### Regulated Contaminants

<i>Disinfectants &amp; Disinfection By-Products</i>	<i>Collection Date</i>	<i>Highest Level Detected</i>	<i>Range of Levels Detected</i>	<i>MCLG</i>	<i>MCL</i>	<i>Units</i>	<i>Violation</i>	<i>Likely Source of Contamination</i>
<i>Total Haloacetic Acids (HAA5)</i>	2024	26	10 – 37	N/A	60	ppb	No	<i>By-product of drinking water chlorination</i>
<i>TTHMs [Total Trihalomethanes]</i>	2024	40	20.9 – 64	N/A	80	ppb	No	<i>By-product of drinking water chlorination</i>
<i>Chlorite</i>	2024	0.55	0.26 – 0.55	0.8	1	ppm	No	<i>By-product of drinking water chlorination</i>
<i>Chloramines</i>	2024	3.0	2.84 – 3.3	MRDLG=4	MRDL=4	ppm	No	<i>Water additive used to control microbes</i>

<i>Inorganic Contaminants</i>	<i>Collection Date</i>	<i>Highest Level Detected</i>	<i>Range of Levels Detected</i>	<i>MCLG</i>	<i>MCL</i>	<i>Units</i>	<i>Violation</i>	<i>Likely Source of Contamination</i>
<i>Barium</i>	2024	0.0116	0.0116 – 0.0116	2	2	ppm	No	<i>Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits</i>
<i>Arsenic</i>	2024	2	1.93 – 1.93	0	10	ppb	No	<i>Erosion of natural deposits; Runoff from orchards; Runoff from electronics production wastes</i>
<i>Fluoride</i>	2024	0.7	0.66 – 0.66	4	4	ppm	No	<i>Erosion of natural deposits; Water additive which promotes strong teeth; Fertilizer or Aluminum Factory discharge</i>
<i>Sodium</i>	2024	23	22.9 – 22.9			ppm	No	<i>Erosion from naturally occurring deposits. Used in water softener regeneration</i>

*The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.*

<i>Radioactive Contaminants</i>	<i>Collection Date</i>	<i>Highest Level Detected</i>	<i>Range of Levels Detected</i>	<i>MCLG</i>	<i>MCL</i>	<i>Units</i>	<i>Violation</i>	<i>Likely Source of Contamination</i>
<i>Combined Radium 226/228</i>	1/22/2020	0.86	0.86 - 0.86	0	5	pCi/L	No	<i>Erosion of naturally occurring deposits</i>
<i>Gross alpha excluding radon and uranium</i>	1/22/2020	0.12	0.12 – 0.12	0	15	pCi/L	No	<i>Erosion of naturally occurring deposits</i>

### **Turbidity**

Turbidity Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

NTU – Nephelometric Turbidity Units

	Limit (Treatment Technique)	Level Detected	Violation	Source
<i>Lowest monthly % meeting limit</i>	<i>0.3 NTU</i>	<i>99.5%</i>	<i>No</i>	<i>Soil runoff</i>
<i>Highest single measurement</i>	<i>1 NTU</i>	<i>0.44 NTU</i>	No	<i>Soil runoff</i>

### **Total Organic Carbon**

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violation sections.

### **Violations**

There were no violations for Rend Lake Intercity Water System in 2024.